

DECLARATION OF PERFORMANCE (DoP)
DoPNo. 2021/A22/57

1. Unique identification code of the product-type:

Multicable hanger metal clamp CH, Concrete screw BTS

...

2. Type, batch or serial and lot number or any other element allowing identification of the construction product as required pursuant to Article 275/2013 (VII. 16).

The type and the lot number can be found on the packaging of the product ...

3. Intended use or uses of the construction product, in accordance with the applicable harmonised technical specification, as foreseen by the manufacturer:

Area of application	design of fastening systems	
Product identification number (with size code):	Multicable hanger metal clamp CH (94055CH, 95580CH)	DIN 4102-12:1998-11 EN 13501-2:2019
Fixing	BTS CONCRETE HEXAGON BOLT (9ZG640BTSB, 9ZG655BTSB, 9655TRBC) BTS CONCRETE SCREW D HEAD TX25 (9ZG530BTSPT, 9ZG545BTSPT)	

...

4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required pursuant to Article 275/2013 (VII. 16) edict:

CELO, Roselló, 7 – Pol.Ind. La Bruguera
08211 Castellar del Vallés, Barcelona, Spanyolország

...

5. System or systems for assessing and verifying the constancy and the performance of construction products:

2+ Systems

6. VEIKI-VNL Kft. (VEIKI Villamos Nagylaboratóriumok Kft) has issued the Immutability of the parameters of the essential properties of the construction product certificate No. E-0779 / VNL, according to this document, VEIKI-VNL Kft HU - 1158 Budapest, Vaszgolyó u. 2-4. is a designated body which does:

- the definition of the product type,
- random testing of the product,
- basic inspection of the manufacturing plant and of the factory production control,
- continuous surveillance, inspection and assessment of factory production control performed in the 2+ system and issued the Immutability of the parameters of the essential properties of the construction product certifiacat No. E-0779 /VNL

7. Declared performance

Tensile load capacity (ceiling mounting)		DIN 4102-12:1998-11 EN 13501-2:2019
Fire resistant usage for 90 minutes (E90) load [N]	<u>On concrete structure:</u> BTS+CH 50	
Non-fire resistant usage Load [N]	<u>On concrete structure:</u> BTS+CH 70	
Raw material Thickness of the zinc layer Fire class	Galvanized Steel ≥ 7 A1 (according to EN 13501-1)	
Surface treatment, corrosion protection	zinc plating	

The performance of the product defined in points 1. and 2. , suits to the declared performance indicated in point 7. The manufacturer specified in point 4. is responsible for this declaration of performance.

Date of issue: 06.10.2022.

Signing person in the name and on behalf of the manufacturer:



Angel Copete
Technical Manager
Celo SA



CELO Hungária Kft.
2851 Kőny, Budai út 1/C
Adószám: 13017453-2-11
EU adószám: HU 13017453
Bank: 10810001-5076005-1128006



Lukács Ákos
Product Manager
Celo Hungária Kft.